

Division 15 – Mechanical

General

This standard is not intended to prohibit the use of alternative methods, systems, or products not listed in this document. The Design Team is encouraged to pursue new innovative ideas to enhance the performance of the building systems. If the project team would like an exception to the standards to be considered, the request must be submitted in written form to the FP&C Project Team.

On the TTU main campus, the majority of all buildings are cooled using chilled water from Central Heating and Cooling Plant No. 1 (CHACP1). There are three steam and two electric turbine driven chillers in the plant designed to operate at a chilled water ΔT of 16 degrees Fahrenheit. Chilled water is distributed to the buildings in a network of piping located in underground utility tunnels. The network has three pairs of 30" pipes that leave the plant and connect to each building through a series of smaller branch pipes. There are also a number of pipes that connect the main pipes to each other for improved distribution. Each building has one or more booster pumps that are intended to overcome friction loss through the building piping, cooling coils, and valves. Future project locations, demands, and CHACP1 capacities will determine design and tie in capabilities.

The following mechanical system items shall be completed and approved by the FP&C Project Team prior to requesting the University to provide chilled water or steam from the campus distribution system:

1. All chilled and hot water piping systems must be complete.
2. All hydronic-piping systems must be cleaned in accordance with TTU Standards.
3. All chilled water piping must be insulated and sealed.
4. All pumps, air handlers and other and other associated equipment must be installed in their permanent location with all valves, strainers, piping, vibration isolation, electrical connections and safety devices in place.
5. Controls to regulate temperature and water flow must be in place and operational.
6. Provide and service fine mesh construction inserts in pump strainers.
7. Temporary filters must be installed on AHU's and fan powered VAV boxes during construction. Provide temporary filter media ahead of permanent filters and replace when dirty. Under no circumstance shall any AHU be started without temporary protective filters installed. All spacers shall be installed and filters tight prior to starting air handling equipment. All permanent filters for air handlers must be in place at substantial completion.
8. Factory startup of the VFD drives shall be completed prior to turning on units.

Equipment layout including but not limited to AHU's, pumps, piping, water heaters, VFD's, PRV Stations, fire pumps, and flow meters will be approved by the Owner or Owner's Representative.

All equipment/systems shall be installed per manufacturer's recommendations.

The campus furnished utilities will be measured by a BAS Energy Measurement System that shall be built and calibrated by a single manufacturer. A certificate of NIST traceable calibration shall be provided with each system component. All equipment shall be covered by the manufacturer's two year warranty.

Avoid whenever possible installing mechanical/electrical equipment, where future access is required, above hard ceilings. If access cannot be obtained through the removable ceiling or through other means, the Contractor shall provide access doors as specified in Division 8. Equipment is to be "readily accessible" per ANSI/ASHRAE standards.

In no case shall PVC piping be installed in a return air plenum or supply/return ductwork without UL Listed and ASTM tested fire resistant plenum wrap. Plenum wrap to be 3M Fire Barrier Plenum Wrap 5A+ or approved equal.

For the safety of the workers and the spirit of LEED, mechanical rooms, fire pump rooms, and electrical rooms lighting shall be controlled by a programmable digital time switch. Specify the WattStopper TS-400 or approved equal. Motion or timer actuated lighting will not be allowed in elevator machine rooms and hoistways.

When performing hydrostatic testing on piping, leave all pipe joints un-covered for visual inspection.

Specify adjustable angle thermometers. Solar powered thermometers will not be specified.

Subcontractors are to provide their own test sheets and test certificates for all mechanical testing. All testing or certifications are to be witnessed by the FP&C Project Inspector or appointed Owner's Representative and appropriate documentation is to be forwarded to the Project Manager within 5 days of the test.

For RO water, specify the Onicon Series F-1100 single turbine flow meter or approved equal for lines 2" and smaller. Specify the Onicon Series F-1200 inline electromagnetic flow meter or approved equal for lines 2 1/2" and larger. Locate meters in an accessible area in the mechanical room of the building being served. Meters shall communicate to BMS via BACnet D-100 controller.

For compressed air, specify the Onicon series F-2600 inline vortex mass flow meter. Utilize ANSI Class 150 pressure sensor with external 24 VDC. Meters shall communicate to BMS via BACnet transmitter.

Energy Conservation Design

Unless noted otherwise, the Design Professionals shall certify that the project complies with the Energy Conservation Standard and submit a copy of that certification to the State Energy Conservation Office

Revised 02-14-2018

(SECO) at least thirty calendar days prior to start of construction. This certification form can be found on the SECO website at: <http://www.seco.cpa.state.tx.us/> . The design team shall provide TTUS three bound copies containing the completed certification form and all necessary information and calculations to support certification. The project should be designed and built to meet the minimum LEED BC+D certification standards.

Pursuant to Texas Government Code 447.004 subsection (a) and the Texas Administrative Code Title 34, Part 1, Chapter 19, Subchapter C § 19.32, the State Energy Conservation Office has adopted, by reference, the latest version of the American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE)/ Illuminating Engineering Society of North America (IESNA), Energy Standard for Buildings Except Low-Rise Residential Buildings. The new standard is ASHRAE/IESNA Standard 90.1-2010. This change applies to any construction or major renovation project with a design assignment date of September 1, 2011 or later.

Pipe and Pipe Fittings

All piping materials shall be manufactured and tested according to applicable NFPA, ANSI, ASTM, ASME, AWWA, U.L., FM Global and CISPI standards.

Unless otherwise noted, all piping materials shall be domestically manufactured in the U.S.A.

Provide a minimum of 12 gauge tracer wire for all below grade non-metallic piping systems. Metallic warning tape shall not be considered equivalent.

Mechanical Identification

Specify to submit list of wording, symbols and letter size coding for all mechanical identification.

Specify to submit valve charts and schedules, including valve tag, number, location, function and valve manufacturer's name and model number.

Plastic nameplates to be laminated, 2-layer minimum, plastic with engraved black letters on light contrasting background color. Nameplate size minimum of 4 inches wide by 1-1/2" high. Letters to be 5/8" in height. Install with stainless steel mechanical fasteners.

Metal tags to be brass, with stamped letters; tag size minimum 1-1/2" diameter with smooth edges. Install with corrosive-resistant chain.

Specify to furnish valves with 1-1/2" diameter brass valve tag with stamped and black-filled numbers. Service designations shall be 1/4" letters, and valve numbers shall be 1/2" letters. Service designations shall be approved by Architect/Engineer. Secure tags to valves by use of brass "S" hooks and brass chain. Secure chain to valve by use of copper or Monel meter seals. Mount charts and drawings listing functions of each valve and its location in a metal frame and behind glass placed as directed. In addition on the record drawings, mark the symbols and furnish a valve schedule properly identifying the valve number and service with the exact location, the material being piped, and the room number of area that the valve services.

Revised 02-14-2018

Piping Identification

Pipe identification shall be in accordance with the latest standards of ASME A13.1 and ANSI.

For underground piping, specify bright colored continuously printed non-detectable plastic ribbon tape. Ribbon shall be not less than six (6) inches wide by minimum four (4) mil thick, and shall be manufactured for direct burial service. Refer also to Division 2 and TTU Operating Policies and Procedures 61.11 *“Underground Trenching of Utilities”* for more specifics.

Specify that plastic pipe markers shall be pre-coiled or snap on type with markings to convey fluid and direction of flow. Approved manufacturers: W.H. Brady Company, Craftmark, 3M, Seton, or equal approved by Architect/Engineer and Owner’s Representative. Locate identification at pumps, at each side of penetration of structure or enclosure, at each obstruction, and every 20 foot of horizontal or vertical runs.

Only stenciled/painted markers shall be allowed outdoors unless the plastic markers are demonstrated to be durably suitable for that service (adhesion, fading, cracking, etc.). Where plastic markers are accepted for outside service, provide clear protective coating recommended by manufacturer.

Insulation - General

Applicator shall be a company specializing in insulation application with minimum 5 years’ experience. References will be made available upon request.

Before installing insulation, build mockups for each type of insulation and finish to demonstrate quality of insulation application and finishes. Build mockups in the location indicated or, if not indicated, as directed by Owner. Use materials indicated for the completed Work. Mockups shall include piping insulation, ductwork insulation and equipment insulation.

Pipe Insulation

This section shall be followed for minimum requirements for all pipe insulation common to several mechanical piping systems. It shall include all insulation, fittings and jacketing. The manufacturer’s installation instructions shall be referenced for each and every insulation application, and the insulation shall be installed in accordance with manufacturer’s installation instructions.

Subject to compliance with requirements, provide products by one of the following:

1. Cellular-Glass Insulation:
 - a. Pittsburgh Corning “Foamglas” or approved equal
2. Flexible Elastomeric Thermal Insulation:
 - a. Armstrong World Industries, Inc.
 - b. Rubatex Corp.
3. Calcium Silicate Insulation:

- a. Owens-Corning Fiberglas Corp.
 - b. Johns-Manville-Thermo-12
4. Fiberglass:
- a. Johns Manville
 - b. Owens Corning
 - c. Pittsburgh Corning

Cellular-glass insulation to be inorganic foamed or cellulated glass, annealed, rigid, hermetically sealed cells, incombustible.

- 1. Preformed Pipe Insulation, without Jacket: Comply with ASTM C 552, Type II, Class 1.
- 2. Preformed Pipe Insulation, with Jacket: Comply with ASTM C 552, Type II, Class 2.

Flexible elastomeric thermal insulation to be closed-cell, sponge- or expanded-rubber materials. Comply with ASTM C 534, Type I for tubular materials and Type II for sheet materials.

- 1. Adhesive: As recommended by insulation material manufacturer.
- 2. Ultraviolet-Protective Coating: As recommended by insulation manufacturer.

Calcium silicate insulation is to be preformed pipe sections of noncombustible, inorganic, hydrous calcium silicate with a non-asbestos fibrous reinforcement. Comply with ASTM C 533, Type I. Johns-Manville Thermo-12 Insulation is the standard calcium silicate insulation for use at Texas Tech.

Fiberglass insulation to be one piece molded insulation with fire retardant multi-purpose all service jacket with a flame/smoke rating of 25-50. Temperature service range of -20 °F to 180 °F.

Prefabricated thermal insulating fitting covers shall comply with ASTM C 450 for dimensions used in pre-forming insulation to cover valves, elbows, tees, and flanges.

Specify field applied jackets as:

- 1. General: ASTM C 921, Type 1, unless otherwise indicated.
- 2. Foil and Paper Jacket: Laminated, glass-fiber-reinforced, flame-retardant kraft paper and aluminum foil.
- 3. PVC Jacket: High-impact, ultraviolet-resistant PVC; 20 mils thick; roll stock ready for shop or field cutting and forming.
 - a. Adhesive: As recommended by insulation material manufacturer.
 - b. PVC Jacket Color: White or gray.
 - c. PVC Jacket Color: Color-code piping jackets based on materials contained within the piping system, and in accordance with ASME A13.1.
- 4. Heavy PVC Fitting Covers: Factory-fabricated fitting covers manufactured from 30-mil thick, high-impact, ultraviolet-resistant PVC.
 - a. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply

- covers for lavatories for the disabled.
- b. Adhesive: As recommended by insulation material manufacturer.
5. Standard PVC Fitting Covers: Factory-fabricated fitting covers manufactured from 20-mil-thick, high-impact, ultraviolet-resistant PVC.
- a. Shapes: 45- and 90-degree, short- and long-radius elbows, tees, valves, flanges, reducers, end caps, soil-pipe hubs, traps, mechanical joints, and P-trap and supply covers for lavatories for the disabled.
 - b. Adhesive: As recommended by insulation material manufacturer.
6. Aluminum Jacket: Aluminum roll stock, ready for shop or field cutting and forming to indicated sizes. Comply with ASTM B 209, 3003 alloy, H-14 temper.
- a. Finish and Thickness: Smooth finish, 0.010 inch (0.25 mm) thick.
 - b. Finish and Thickness: Corrugated finish, 0.016 or 0.020 inch thick.
 - c. Moisture Barrier: 1-mil- thick, heat-bonded polyethylene and kraft paper.
 - d. Elbows: Preformed, 45- and 90-degree, short- and long-radius elbows; same material, finish and thickness as jacket.
7. Preformed Aluminum Jacket: ASTM 0.020 inch thick; factory cut and rolled to indicated sizes.

Apply insulation materials, accessories, and finishes according to the manufacturer's written instructions; with smooth, straight, and even surfaces; free of voids throughout the length of piping, including fittings, valves, and specialties.

Unless otherwise indicated, do not apply insulation to the following systems, materials, and equipment:

1. Flexible connectors.
2. Vibration-control devices.
3. Fire-suppression piping.
4. Below-grade piping, unless otherwise indicated by Design Professional.
5. Chrome-plated pipes and fittings, unless potential for personnel injury.
6. Air chambers, unions, strainers, check valves, plug valves, and flow regulators.
7. Steam traps and condensate cooling (drip) legs.

Interior Insulation Application Schedule:

Service: Domestic hot and re-circulated hot water

1. Insulation Material: One-piece molded fiberglass
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: Per Design Professional
4. Vapor Retarder Required: Per Design Professional

Service: Domestic water

1. Insulation Material: One-piece molded fiberglass

Revised 02-14-2018

2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: Per Design Professional
4. Vapor Retarder Required: Per Design Professional

Service: Condensate drain piping

1. Insulation Material: Flexible elastomeric
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: None
4. Vapor Retarder Required: Yes

Service: Exposed sanitary drains and domestic water supplies and stops for fixtures for the disabled

1. Insulation Material: Flexible elastomeric
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: PVC P-trap and supply covers
4. Vapor Retarder Required: No

Service: Chilled-water supply and return

1. Insulation Material: Tunnels and Mechanical Rooms to be Foamglass or equal. Interior spaces to be fiberglass or equal
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: Mechanical Room and Tunnel to have aluminum jacket with stainless steel bands
4. Vapor Retarder Required: Yes

Service: Refrigerant suction and hot-gas piping

1. Insulation Material: Flexible elastomeric
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: Per Design Professional
4. Vapor Retarder Required: Yes

Service: Heating hot-water supply and return

1. Insulation Material: One-piece molded fiberglass
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: interior building spaces per Design Professional and Aluminum in tunnel
4. Vapor Retarder Required: Per Design Professional

Service: Steam and condensate

1. Insulation Material: Calcium silicate
2. Insulation Thickness: Per Design Professional

Revised 02-14-2018

3. Field-Applied Jacket: Aluminum or fiberglass Per Design Professional
4. Vapor Retarder Required: Yes

Exterior Insulation Application Schedule:

This application schedule is for aboveground insulation outside the building.

Service: Refrigerant suction

1. Insulation Material: Flexible elastomeric
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: Per Design Professional
4. Vapor Retarder Required: Yes

Service: Chilled-water supply and return.

1. Insulation Material:
 - a. Pittsburgh Corning “FoamGlass” or approved equal , with jacket (tunnel Applications).
 - b. One-piece molded fiberglass.
2. Insulation Thickness: Per Design Professional
3. Field-Applied Jacket: Aluminum
4. Vapor Retarder Required: Yes.

All underground steam and condensate lines shall be Thermacor, Permapipe, or an approved equal pre-insulated pipe.

Duct Insulation

This section shall be followed for all semi-rigid and flexible duct, plenum, and breeching insulation; insulating cements; field-applied jackets; accessories and attachments; and sealing compounds.

Specify to factory label insulation and jacket materials and sealer and cement material containers with appropriate markings of applicable testing and inspecting agency.

For insulation installed indoors, specify flame-spread rating of 25 or less, and smoke-developed rating of 50 or less.

For insulation installed outdoors, specify flame-spread rating of 75 or less, and smoke-developed rating of 150 or less.

Subject to compliance with requirements, provide products by one of the following for mineral-fiber insulation:

1. CertainTeed Manson.
2. Knauf FiberGlass GmbH.
3. Owens-Corning Fiberglas Corp.

Revised 02-14-2018

4. Mansville

Mineral-fiber board thermal insulation to be glass fibers bonded with a thermosetting resin. Comply with ASTM C 612, Type IB, without facing and with all-service jacket manufactured from kraft paper, reinforcing scrim, aluminum foil, and vinyl film.

Mineral-fiber blanket thermal insulation to be glass fibers bonded with a thermosetting resin. Comply with ASTM C 553, Type II, without facing and with all-service jacket manufactured from kraft paper, reinforcing scrim, aluminum foil, and vinyl film.

Specify field applied jackets as:

1. General: ASTM C 921, Type 1, unless otherwise indicated.
2. All service FSK (Foil Scrim Craft) jacket: Foil and Paper Jacket: Laminated, glass-fiber-reinforced, flame-retardant kraft paper and aluminum foil.
3. PVC Jacket: High-impact, ultraviolet-resistant PVC; 20 mils thick; roll stock ready for shop or field cutting and forming.
 - a. Adhesive: As recommended by insulation material manufacturer.
 - b. PVC Jacket Color: White or gray.
 - c. PVC Jacket Color: Custom color selected by the Project Manager.
4. Aluminum Jacket: Deep corrugated sheets manufactured from aluminum alloy complying with ASTM B 209, and having an integrally bonded moisture barrier over entire surface in contact with insulation. Metal thickness and corrugation dimensions are scheduled at the end of this Standard.
 - a. Finish: Smooth finish.
 - b. Finish: Cross-crimp corrugated finish.
 - c. Finish: Stucco-embossed finish.
 - d. Finish: Factory-painted finish.
 - e. Moisture Barrier: 1-mil-thick, heat-bonded polyethylene and kraft paper.

Apply insulation materials, accessories, and finishes according to the manufacturer's written instructions; with smooth, straight, and even surfaces; and free of voids throughout the length of ducts and fittings.

Specify to seal insulation material with glass fab membrane imbedded with adhesive. Foil tape will only be allowed with written approval from the Owner's Representative.

Insulate the following plenums and duct systems:

1. Indoor concealed supply, return and outside air ductwork.
2. Indoor exposed supply, return and outside air ductwork.
3. Outdoor exposed supply and return ductwork.
4. Indoor exposed range hood exhaust ductwork.

Revised 02-14-2018

5. Indoor concealed range hood exhaust ductwork (2 hour UL Rated)
6. Indoor exposed oven and dishwasher exhaust ductwork.
7. Indoor concealed oven and dishwasher ductwork.

Items not insulated unless otherwise indicated. Do not apply insulation to the following systems, materials, and equipment:

1. Fibrous-glass ducts.
2. Metal ducts with duct liner.
3. Factory-insulated flexible ducts.
4. Factory-insulated plenums, casings, terminal boxes, and filter boxes and sections.
5. Flexible connectors.
6. Vibration-control devices.
7. Testing agency labels and stamps.
8. Nameplates and data plates.
9. Access panels and doors in air-distribution systems.

No supply air duct shall be internally insulated unless approved by the FP&C Project Team for particular project specifics.

Indoor Duct and Plenum Application Schedule:

Service: Round, supply-air ducts, concealed or exposed

1. Material: Mineral-fiber blanket
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth or foil and paper
5. Vapor Retarder Required: Yes

Service: Round, return-air ducts, concealed or exposed

1. Material: Mineral-fiber blanket
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth or foil and paper
5. Vapor Retarder Required: Yes

Service: Round, outside-air ducts, concealed or exposed

1. Material: Mineral-fiber blanket
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth or foil and paper
5. Vapor Retarder Required: Yes

Service: Rectangular, supply-air ducts, concealed or exposed

1. Material: Mineral-fiber blanket
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth or foil and paper
5. Vapor Retarder Required: Yes

Service: Rectangular, return-air ducts, concealed or exposed

1. Material: Mineral-fiber blanket
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth or foil and paper
5. Vapor Retarder Required: Yes

Service: Rectangular, outside-air ducts, concealed or exposed

1. Material: Mineral-fiber blanket
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth or foil and paper
5. Vapor Retarder Required: Yes

Service: Rectangular, range-hood exhaust ducts, concealed or exposed

1. Material: Mineral-fiber board
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth
5. Vapor Retarder Required: Yes

Service: Rectangular, dishwasher exhaust ducts, concealed or exposed

1. Material: Mineral-fiber board or mineral-fiber blanket
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth
5. Vapor Retarder Required: Yes

Outdoor Duct and Plenum Application Schedule:

Service: Round, supply-air ducts.

1. Material: Mineral-fiber board
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One

Revised 02-14-2018

4. Field-Applied Jacket: Glass cloth
5. Field Applied Jacket: FSK Material
6. Field Applied Jacket: PVC
7. Field Applied Jacket: Aluminum
 - a. Aluminum Thickness: Per Design Professional Requirements
 - b. Corrugation Dimension: Per Design Professional Requirements
8. Field-Applied Jacket: Stainless steel.
 - a. Corrugation Dimension: Per Design Professional Requirements
9. Vapor Retarder Required: Yes

Service: Round, return-air ducts

1. Material: Mineral-fiber board
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth
5. Field Applied Jacket: Foil and paper
6. Field Applied Jacket: PVC
7. Field Applied Jacket: Aluminum
 - a. Aluminum Thickness: Per Design Professional Requirements
 - b. Corrugation Dimension: Per Design Professional Requirements
8. Field-Applied Jacket: Stainless steel.
 - a. Corrugation Dimension: Per Design Professional Requirements
9. Vapor Retarder Required: Yes

Service: Rectangular, supply-air ducts.

1. Material: Mineral-fiber board
2. Thickness: Per Design Professional Requirements
3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth
5. Field Applied Jacket: Foil and paper
6. Field Applied Jacket: PVC
7. Field Applied Jacket: Aluminum
 - a. Aluminum Thickness: Per Design Professional Requirements
 - b. Corrugation Dimension: Per Design Professional Requirements
8. Field-Applied Jacket: Stainless steel.
 - a. Corrugation Dimension: Per Design Professional Requirements
9. Vapor Retarder Required: Yes

Service: Rectangular, return-air ducts.

1. Material: Mineral-fiber board
2. Thickness: Per Design Professional Requirements

Revised 02-14-2018

3. Number of Layers: One
4. Field-Applied Jacket: Glass cloth
5. Field Applied Jacket: Foil and paper
6. Field Applied Jacket: PVC
7. Field Applied Jacket: Aluminum
 - a. Aluminum Thickness: Per Design Professional Requirements
 - b. Corrugation Dimension: Per Design Professional Requirements
8. Field-Applied Jacket: Stainless steel.
 - a. Corrugation Dimension: Per Design Professional Requirements
9. Vapor Retarder Required: Yes

Valves

This section shall be followed for all valves common to several mechanical piping systems. It shall include all valves and connections.

Use gate valves for isolation and shut off duty. Do not use for throttling or balancing duty.

Gate Valves, 2-1/2 Inches and Smaller: Class 125, 200-psi cold working pressure (CWP), or Class 150, 300-psi CWP; cast-bronze body and bonnet, solid-bronze wedge, rising stem, teflon-impregnated packing with bronze packing nut, threaded or soldered end connections; and with malleable-iron hand wheel.

Gate Valves, 3 Inches and Larger: Class 125, 200-psi CWP, cast-iron body and bonnet, solid cast-iron wedge, brass-alloy stem, outside screw and yoke, teflon-impregnated packing with 2-piece packing gland assembly, flanged end connections; and with cast-iron hand wheel.

Ball valves shall be used for all isolation type applications, except in steam systems. Ball valves may also be used for throttling duties. It is recommended ball valves larger than 6" not be used.

Ball Valves, 2-1/2 Inches and Smaller: Class 125, 200-psi CWP, or Class 150, 300-psi CWP, bronze body and bonnet, 2-piece construction; chrome-plated brass ball, full size port; blowout proof; bronze or brass stem; teflon seats and seals; threaded or soldered end connections:

1. Operator: Vinyl-covered steel lever handle.
2. Stem Extension: For valves installed in insulated piping.
3. Memory Stop: For operator handles.

Ball Valves, 3 Inches thru 6 inches: Class 125, 200-psi CWP, or Class 150, 300-psi CWP, bronze body and bonnet, 2-piece construction; chrome-plated brass ball, full size port; blowout proof; bronze or brass stem; teflon seats and seals; flanged end connections:

1. Operator: Lever operators with lock.

Revised 02-14-2018

2. Stem Extension: For valves installed in insulated piping.
3. Memory Stop: Where required.

Plug valves shall be used only for shut off duty.

Plug Valves: 175-psi CWP, cast-iron body and bonnet, cast-iron plug, teflon packing, flanged end connections:

1. Operator: Lever or Square head.

Globe valves maybe used for both shut off and throttling duty.

Globe Valves, 2-1/2 Inches and Smaller: Class 125, 200-psi CWP, or Class 150, 300-psi CWP; cast-bronze body and screwed bonnet, bronze, or teflon disc, silicon bronze-alloy stem, teflon-impregnated packing with bronze nut, threaded or soldered end connections; and malleable-iron hand wheel.

Globe Valves, 3 Inches and Larger: Class 125, 200-psi CWP, cast-iron body and bolted bonnet with bronze fittings, renewable bronze seat and disc, brass-alloy stem, outside screw and yoke, teflon-impregnated packing with cast-iron follower, flanged end connections; and with cast-iron hand wheel.

Butterfly valves may be used for both shut off and throttling duty.

Butterfly Valves: 200-psi CWP, 150-psi maximum pressure differential, cast-iron body and bonnet, extended neck, stainless-steel stem, field-replaceable EPDM or Buna N sleeve and stem seals, lug style:

1. Disc Type: Aluminum bronze.
2. Operator for Sizes 2 Inches to 6 Inches: Lever handle with latch lock.

Swing Check Valves, 2-1/2 Inches and Smaller: Class 125, 200-psi CWP, or Class 150, 300-psi CWP; horizontal swing, Y-pattern, cast-bronze body and cap, rotating bronze disc with composition seat, threaded end connections:

Swing Check Valves, 3 Inches and Larger: Class 125, 200-psi CWP, cast-iron body and bolted cap, horizontal-swing bronze disc, flanged end connections.

Wafer Check Valves: Class 125, 200-psi CWP, cast-iron body, bronze disc/plates, stainless-steel pins and springs, Buna N seals, installed between flanges.

Lift Check Valves: Class 125, bronze body and cap (main components), horizontal or vertical pattern, lift-type, bronze disc with stainless-steel holder threaded or soldered end connections.

Isolation valves for steam supply shall be gate valves. Valves for condensate return shall be steam rated ball valves or OS&Y gate valves.

Revised 02-14-2018

Installation of valves:

1. Install valves in horizontal piping with stem at or above the center of the pipe.
2. Install valves in a position to allow full stem movement.
3. For chain-wheel operators, extend chains to 60 inches above finished floor elevation.
4. Installation of Check Valves: Install for proper direction of flow as follows:
 - a. Swing Check Valves: Horizontal position with hinge pin level.
 - b. Wafer Check Valves: Horizontal or vertical position, between flanges.
 - c. Lift Check Valve: With stem upright and plumb.

All soldered joints shall be made with high temperature solid string or wire solder, 95% tin, 5% antimony, using non-corrosive paste flux. 50-50 or 40-60 low temperature solder shall not be used. Select valves with the following ends or types of pipe/tube connections:

1. Copper Tube Size, 2 Inches and Smaller: Solder ends, except provide threaded ends for heating hot water and low-pressure steam service.
2. Steel Pipe Sizes, 2 Inches and Smaller: threaded.
3. Steel Pipe Sizes, 2 ½ Inches and Larger: flanged.

Application Schedule:

Use gate, ball, and butterfly valves for shutoff duty; globe, ball, and butterfly for throttling duty.

Application Schedule:

Domestic Water Systems: Use the following valve types:

1. Gate Valves: Class 125, bronze or cast-iron body to suit piping system.
2. Ball Valves: Class 150, 300-psi CWP, with stem extension.
3. Plug Valves: Neoprene-faced plug, Buna N packing.
4. Globe Valves: Class 125, bronze or cast-iron body to suit piping system, and bronze disc.
5. Butterfly Valves: Nickel-plated ductile iron disc; EPDM sleeve and stem seals.
6. Bronze Swing Check: Class 125, with rubber seat.
7. Check Valves: Class 125, swing or wafer type as indicated.

Heating Water Systems: Use the following valve types:

1. Gate Valves: Class 150, bronze or cast-iron body to suit piping system.
2. Ball Valves: Class 150, 300-psi CWP, with stem extension and memory stop.
3. Plug Valves: teflon packing.
4. Globe Valves: Class 150, bronze or cast-iron body to suit piping system, and bronze disc.
5. Butterfly Valves: Nickel-plated ductile iron disc; EPDM sleeve and stem seals.
6. Bronze Swing Check: Class 150, with composition seat.
7. Check Valves: Iron swing, wafer, or lift type, as indicated. Swing check shall be Class 150 with bronze seat ring.

Steam and Condensate Return Systems: Use the following valve types:

Revised 02-14-2018

1. Gate Valves: Class 150, bronze body; or Class 125, cast-iron body.
2. Ball Valves: Class 150, 300-psi CWP, with stem extension.
3. Plug Valves: teflon packing.
4. Globe Valves: Class 150, bronze body with teflon disc; or Class 125, cast-iron body.
5. Check Valves: Class 150, bronze body swing check with composition seat; Class 150, cast-iron body swing check with bronze seat ring; or Class 125, cast-iron body wafer check.

Chilled-Water Systems: Use the following valve types:

1. Gate Valves: Class 150, bronze body; or Class 125, cast-iron body.
2. Ball Valves: Class 150, 300-psi CWP, with stem extension and memory stop.
3. Plug Valves: Buna N packing.
4. Globe Valves: Class 125, bronze body with bronze disc; or Class 125, cast-iron body.
5. Butterfly Valves: Nickel-plated ductile iron disc; EPDM sleeve and stem seals.
6. Check Valves: Class 125, bronze body swing check with rubber seat; Class 125, cast-iron body swing check; or Class 125, cast-iron body lift check.

Condenser Water Systems: Use the following valve types:

1. Gate Valves: Class 125, bronze body; or Class 125, cast-iron body.
2. Ball Valves: Class 150, 300-psi CWP, with memory stop.
3. Plug Valves: Buna N packing.
4. Globe Valves: Class 125, cast iron body with bronze disc; or Class 125.
5. Butterfly Valves: Aluminum bronze disc; EPDM sleeve and stem seals.
6. Check Valves: Class 125, cast-iron body swing check with rubber seat

Hydronic Piping

This section shall be followed for all hydronic piping common to several mechanical systems. Standard includes piping, special-duty valves, and hydronic specialties for hot-water heating, chilled-water cooling, and condenser water systems; makeup water for these systems; blowdown drain lines; and condensate drain piping.

Materials:

Drawn-Temper Copper Tubing: Type L Hard Drawn for interior water lines.

Hard-Drawn Copper Tubing: Type L Hard-Drawn tubing for all below grade or below slab water lines.

Steel Pipe, 2" and Smaller: Schedule 40, black steel, threaded ends.

Steel Pipe, 2-1/2" through 12": Type E (electric-resistance welded), Grade A, Schedule 40, black steel, plain ends.

Revised 02-14-2018

Steel Pipe, 14” through 18”: Type E (electric-resistance welded), Grade B, Schedule 30, black steel, plain ends.

Steel Pipe, 20”: Type E (electric-resistance welded), Grade B, Schedule 20, black steel, plain ends.

Steel Pipe Nipples: made of Schedule 40, black steel; seamless for 2” and smaller and electric-resistance welded for 2-1/2” and larger.

Cast-Iron Threaded Fittings: Classes 125 and 250.

Malleable-Iron Threaded Fittings: Classes 150 and 300.

Malleable-Iron Unions: Classes 150, 250, and 300.

Cast-Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; raised ground face, and bolt holes spot faced.

Wrought-Steel Fittings: wall thickness to match adjoining pipe.

Wrought Cast- and Forged-Steel Flanges and Flanged Fittings: including bolts, nuts, and gaskets of the following material group, end connections, and facings:

1. Material Group: 1.1.
2. End Connections: Butt welding.
3. Facings: Raised face.

Welding Materials: Comply with Section II, Part C, of the ASME Boiler and Pressure Vessel Code for welding materials appropriate for wall thickness and for chemical analysis of pipe being welded.

Gasket Material: Thickness, material, and type suitable for fluid to be handled; and design temperatures and pressures.

Underground pre-insulated pipe shall be PERMA-PIPE or Thermacor.

PVC and CPVC Piping shall not be used in hydronic piping systems.

Piping Applications:

Hot and Chilled Water: 2” and smaller, aboveground, use Type L drawn-temper copper tubing with soldered joints. Below ground or within slabs, use Type K annealed-temper copper tubing with soldered joints. Use the fewest possible joints below ground and within slabs.

Hot and Chilled Water, 2-1/2” and Larger: Schedule 40 steel pipe with welded and flanged joints.

Revised 02-14-2018

Condensate Drain Lines: Type L drawn-temper copper tubing with soldered joints.

Chilled Water

The chilled water piping will include a de-coupler piping design that allows the incoming chilled water to circulate through the building system and is separated from the tunnel and other chiller systems by an interconnecting pipe from the supply and return piping. The chilled water shall circulate through the building chilled water pumps supplying as much cooling to the building without sacrificing comfort. “Cross feeding” or “short-circuiting” of the supply and return waters shall be prevented by having actuated modulating valves to return chilled water back to the tunnel or chiller at an adjustable set point temperature of 55 degrees F. The modulating valve shall be on the return line.

Specify the Onicon Series F-3500 insertion type electromagnetic flow meter or approved equal for lines 3” and larger. Specify the Onicon Series F-3100 inline electromagnetic flow meter or approved equal for lines 2 1/2” and smaller. Locate meters in an accessible area in the mechanical room of the building being served. Provide a BTU meter equal to the Onicon System-10 BTU Meter. Meters shall communicate to BMS via BACnet System 10 controller.

Steam and Condensate Piping

This Section provides for furnishing and installing low pressure (125 psig and below) steam and condensate piping, fittings, valves, strainers, vents and steam traps in tunnels, valve pits, building crawlspace and building mechanical and pump rooms.

For Steam Condensate piping 2” and smaller in diameter, use ASTM A 53, Grade A or B, Schedule 80 seamless black steel pipe with forged steel class 300 socket weld fittings conforming with ASME B16.11.

For Steam piping 2” and smaller in diameter, use Schedule 40, seamless black steel pipe with class 300 black cast iron malleable iron threaded fittings.

For Steam pipe 2½” through 10” in diameter, use ASTM A 53, Grade A or B, seamless black steel pipe with seamless steel welding fittings conforming with ASTM A 234, Grade WPA or WPB, ANSI B16.9; standard weight for steam and Schedule 80 for condensate piping.

Provide traps where indicated or required, at least every 150’ of straight run and at all steam risers and expansion joints. For pressures up to 60 psi, use float and thermostatic type. Fabricate body and covers of traps of cast iron.

Steam system shall utilize flash tanks if different pressures of systems feed to condensate.

Revised 02-14-2018

Specify to install a steam flow meter on each system. Specify the Onicon Series F-2600 inline vortex mass flow type flow meter or approved equal. Optimize pressure sensors. Locate meters in an accessible area in the mechanical room of the building being served. Meter shall communicate to BMS via BACnet D-100 controller.

For condensate, specify the Onicon Series F-3000 inline electromagnetic flow meter or approved equal. Meter shall communicate to BMS via BACnet D-100 controller.

Steam and Condensate Pumps

Specify steam pumps to be steam powered non-electric whenever possible. Design considerations include pumping distance to the main return pipe, back pressure in the main return pipes, amount of condensate designed to be pumped back, and space limitations in the mechanical room. Specify Spirax Sarco pressure power pumps and steam traps or approved equal.

Specify vertical centrifugal pumps capable of pumping condensate at full capacity at boiling temperature. Provide duplex-type pumps with pressure gauges that are close coupled and bronze fitted.

Furnish a cast-iron receiver tank with strainer. Provide the necessary float switches and alternator. Alternate the pumps and give standby service automatically. Furnish a receiver with condensate return, vent overflow, drain connections, water level gauge, thermometer and strainer.

Mount NEMA II control cabinet on the unit; include magnetic starters, circuit breakers, cover interlock, alternator, test button and fused control circuit transformer. Provide Domestic Series CB.

Specify Spence pressure reducing valves (PRV's) and steam pilots or approved equal.

Natural Gas Piping

Within two (2) feet of building line and above grade in accessible locations for 2" or smaller, specify black steel ASTM A53 standard weight with 150 pound black malleable screwed fittings. For 2 ½ " and larger, specify black steel ASTM A53 standard weight with welded joints and fittings.

Within two (2) feet of building line in sleeve above grade and in inaccessible areas (e.g., in walls, or in chases) all sizes shall have welded joints.

Below grade and outside of two (2) feet of building line (exact demarcation may vary due to site conditions) unless otherwise indicated, below grade gas piping shall be PE2406 polyethylene pipe and shall comply with ASTM D2513. Tracer wire shall be spirally wrapped around the pipe (minimum of 1

revolution for every 3 feet of pipe). All sizes shall be IPS, NIPAC, Driscopipe 6500, or equal approved by Engineer.

Below Grade fittings shall be butt fusion complying with ASTM D3261, or socket fusion complying with ASTM D2683. All branch connections shall be made using tees. Branch saddle or service saddle with tapping tee shall be allowed only at taps on existing mains.

Underground gas piping shall not be installed in parking lots without the approval from the Owner and Engineer.

Technicians performing fusion process shall be currently certified by the Texas Railroad Commission and shall submit documentation showing experience on comparable fusion procedures within the last twelve (12) months.

With prior approval of Engineer and Owner's Representative, joints and fittings may be of mechanical fitting type. Mechanical fittings shall be IAPMO/UPC listed. Permaset or equal approved by Engineer. Transitions from polyethylene to steel pipe shall be by factory fabricated transition fitting (i.e., Central Double "O" Seal) or transition riser (Central Plastics Part No. 600 Series). Minimum horizontal dimension for transition riser shall be 30 inches. Anodeless service riser may be used when interior carrier pipe complies with the specifications for the location of the pipe.

Where required in select locations and approved by Engineer, underground piping, fittings, and joints shall be black steel with factory coating as described above.

Minimum coverage for gas piping in trenches shall be 36" for low pressure and 46" for high pressure piping. Provide warning tape at 12"-16" below grade in trench as outlined in Division 2.

Specify Onicon F-5200 insertion type thermal mass gas flow meter. Meter shall communicate to BMS via BACnet D-100 controller.

Fire Protection Systems

Specify that the fire protection system design and installation shall conform to the latest editions and requirements of NFPA, International Code Council (ICC) Building Code and ICC Fire Code requirements, Texas Tech Fire Marshall's Office, and FM Global's recommendations. Where latest adopted editions vary between codes, the Texas Tech Fire Marshall's Office is the Authority Having Jurisdiction (AHJ) for all life safety systems.

The work shall be performed by a contractor with a current certificate of registration from the State Fire Marshal as an independent fire protection sprinkler contractor (Registered Firm). The work shall be performed under the supervision of a licensed Responsible Managing Employee (RME) as defined by

Revised 02-14-2018

Texas Insurance Code (TIC), Article 5.43-3, Fire Protection Sprinkler Systems. This contractor shall be fully responsible for all design to meet project requirements, including items exceeding those specifically illustrated or mentioned in the contract documents. The fire protection contractor shall have a minimum of 5 years of experience in the installation of fire protection work of the type specified for this project. References will be made available upon request.

Perform all calculations, prepare and submit shop drawings, and secure all required approvals from approving authorities.

Submittals will be reviewed by the Project's Design Professionals, Texas Tech University Fire Marshal's Office, TTU Facilities Planning and Construction Office, and FM Global.

All materials and equipment, where applicable, should be listed by Underwriters Laboratories and FM Approved and the installation should be in accordance with the manufacturer's recommendations and FM Global Recommended Good Practices.

At start of project, perform new, current flow tests or secure new/current pressure/flow capacity data from Texas Tech University Fire Marshall's office or local water utility in order to verify line size Requirements for the new project. Include flow test data on plans and in submittals.

All systems will be hydraulically designed and shall include a minimum safety factor of 10 psi to account for future variations in water supply pressure, deterioration of piping system and future renovations to system. Hydraulic calculations shall show inclusion of this "safety factor."

If at all possible, install fire riser and fire pump (if required) in a dedicated room.

If required, fire pumps should be sized so that the maximum expected discharge pressure at churn does not exceed 175 psi. If this is not possible, a pressure reducing valve (PRV), set for 175 psi, should be installed after the pump at required locations. The PRV shall be tested upon completion to ensure proper operation under flow and no flow conditions per NFPA 13. All PRV test results shall be recorded on the Contractor's Material and Test Certificate. Means shall also be provided downstream of the PRV to conduct flow tests to simulate the sprinklers system's demand requirements to confirm proper operation of the installed PRV.

Fire pump arrangements shall include an inline flow meter and outside test header.

Arrange the fire pump for manual stop only. According to *FM Global Data Sheet 3-7*, the fire pump should be arranged to automatically start as follows:

1. The jockey pump start point equals the pump pressure at churn (zero flow) plus the Maximum static pump suction pressure plus 5 psi.
2. The jockey pump stop point is 10 psi more than the jockey pump start point.
3. The fire pump start point is 5 to 10 psi less than the jockey pump start point.

Revised 02-14-2018

Connect the electric motor fire pump controller feeder circuit directly to the facility power source ahead of all other facility power loads or as required per the applicable electrical code and FM Global recommendations.

Pipe sizes for the fire pump installations should be in accordance with *FM Global Data Sheet 3-7, Table 1*.

Submit welding procedures and welder's certificates for shop and job site welding of piping work.

Underground piping to be C900 PVC or C151 ductile iron water pipe. Underground piping under footings and penetrating flooring to be Class 300 AWWA C151 ductile iron water pipe or FM approved stainless steel spigot assembly.

No fire protection piping is allowed in IDF/MDF rooms, elevator machine rooms, and electrical rooms except where serving that specific room.

Specify double check backflow preventer assembly, complete with OS&Y valves, and tamper switches. Backflow prevention assembly testers may test and repair assemblies on fire lines only if they are permanently employed by an approved fire line contractor. The State Fire Marshal's office requires that any person performing maintenance on fire lines must be employed by an approved fire line contractor.

Aboveground piping for wet systems to be schedule 40 black steel pipe conforming to ASTM A53 installed with approved screwed, grooved, flanged, and welded fittings. Schedule 40 galvanized pipe will be required for dry systems and pre-action systems. Comply with applicable governing regulations and industry standards. Piping shall be domestically manufactured. All non-galvanized black steel piping used in water based fire protection systems shall be provided with an antimicrobial coating designed to inhibit the growth of microbiologically influenced corrosion (MIC). The use of thin wall sprinkler piping shall not be acceptable.

All piping shall be fully reamed for all joint types.

All grooved pipe to be roll grooved. Cut groove is not acceptable. Repair all pipe coatings disturbed by the grooving process.

All fire protection piping shall be thoroughly flushed to remove any slag or debris prior to being tested or put into service. The system shall be thoroughly flush without sprinkler heads installed.

Screwed pipe fittings to be Class 150 black malleable or Class 125 cast iron fittings.

Mechanical grooved couplings to malleable iron housing clamps to engage and lock "C" shaped elastomeric sealing gasket, steel bolts, nuts, and washers: galvanized for galvanized pipe.

No plain end fittings will be allowed.

All fire sprinkler systems will have an outdoor rated Horn/Strobe that will be activated from water flow on the system mounted outside of the riser room. Water motor gongs and electric bells are not acceptable.

Revised 02-14-2018

All water flow switches, tamper switches, or other supervisory switches will be monitored by the Fire Alarm System. Please refer to Division 16.

Fire pumps should report a “general fire alarm” back to CHACP 1 upon operation.

A post indicating valve will be provided for each building and located as directed by the TTU Fire Marshall’s office.

A fire department connection will be provided for each building and located as directed by the Owner and TTU Fire Marshal’s Office. Specify the fire department connection to be either wall mounted flush type or 90 degree sidewalk type depending on project location. Sidewalk type will be marked with the standard manufacturer FDC marking sign and a metal sign identifying the specific building it serves. The NFPA and TTU required sign will have white raised letters at least one inch in size on a red background. Exact verbiage will be determined by TTU Fire Marshal’s Office.

For pendant heads in finished ceilings, specify white concealed sprinkler heads with round coverplates Unless approved otherwise by the FP&C Project Manager. All sprinkler heads are to be located in the center of the tile (both ways) when possible unless approved otherwise by the FP&C Project Manager. Other pendent sprinkler head options will only be allowed if approved by the TTU Project Manager.

FM approved flexible drop connections are allowed for center of tile applications only.

Fire protection design for each system should include a 1 inch inspector’s test with a smooth bore corrosion resistant orifice giving a flow equal to one sprinkler of a type having the smallest K-factor installed on the system. Inspector’s test should be located at the most accessible remote location. Each system shall include a 2” main drain with gauges for the dual purpose of draining the entire sprinkler system and for conducting future main drain test.

Fire extinguishers shall be 10# ABC with non DOT stamped cylinders unless special hazard areas exist. TTU Fire Marshall’s Office will determine the fire extinguisher type for special hazard areas.

System piping and components will be hydrostatically tested per NFPA 13 requirements. All aboveground and underground pipe joints will remain uncovered during the test for visible inspections. The Contractor will be responsible for the TTU Fire Marshall’s Office inspection fees for any failed test.

FM Global’s Field Engineer and TTU Fire Marshal’s Office shall be notified of all acceptance tests. Please notify the FP&C PM fourteen (14) days in advance for scheduling.

Fire pump acceptance tests will be performed in strict accordance with NPFA and FM Global’s recommendations. FM Global requires the test curve to be developed with a minimum of five (5) test points at 0%, 50%, 100%, 125%, and 150% rated flow. Automatic and manual starts will be performed. Video the final pump acceptance test and submit to the TTU Fire Marshall’s office.

At the end of the one year warranty period, the Fire Protection Subcontractor shall execute a documented annual inspection, acceptable to the TTU Fire Marshall’s Office, without change in the

Contract amount. The Inspection form shall be filled out in triplicate and submitted to the TTU Fire Marshall's Office and TTU Facilities Planning and Construction Office.

Press Connect Fittings

Press connect type fittings will be Viega ProPress System with Smart Connect Feature or approved equal. Press connect type fittings will only be allowed for 2" or smaller. Press connect type fittings will be allowed for domestic water and for chilled and heating water and shall meet the following requirements:

Copper and copper alloy press-connect fittings shall comply with the material and performance requirements of ASME B16.51. Press connect fittings shall have an indicating feature to positively identify un-pressed fittings during testing procedures. All fittings shall be identified as having the indicating feature by markings on the rim of the fittings. The indicating feature shall be created by a mechanical deformation in the metal casing that allows media in the pipe to pass around the sealing element of an un-pressed fitting. No such feature created by deformation of the sealing element shall be permitted. The installers shall clearly mark the depth of each pipe/fitting being pressed for verification and/or inspection that the pipe is fully inserted into the fitting prior to the pressing operation. Each installer shall be factory trained by the manufacturer and shall carry authorized training credentials. Sealing elements shall be recommended by the manufacturer. For water applications, EPDM sealing elements shall be used. Ass fitting systems shall be compatible with Rigid press tools.

Press connect type fittings to have a 50 year warranty against defects in material and workmanship.

Mechanical/plumbing contractor shall furnish the owner a new press fit tool and fitting attic stock per the Owner's requirement.

Plumbing Fixtures and Equipment

Obtain plumbing fixtures, faucets, and other components of each category through one source from a single manufacturer. If fixtures, faucets, or other components are not available from a single manufacturer, obtain similar products from other manufacturers specified for that category.

Specify that electric or gas water heaters are to be sized to meet the project demand and voltage requirements set forth by the A/E. Specify Rheem, AO Smith, or approved equal. Tanks shall have a five year warranty and other components shall have a minimum of a one year warranty from date of substantial completion. Tank shall be UL rated and meet ASME standards with pressure ratings. Safety relief valves shall be ASME rated and be both pressure and temperature sensitive. Units shall be supplied with applicable drain pans.

Specify that steam water heaters are to be factory assembled, instantaneous type, with all controls, valves, safety solenoids, traps, and temperature regulating equipment to provide hot water with adjustable set-points. The unit shall have cupro-nickel (copper nickel) tubes to resist the hard water in this area. Internal baffles when specified shall be Brass or similar metals. Teflon or other similar types of materials will not be allowed. Specify Patterson Kelly or approved equal. All related UL and ASME

Revised 02-14-2018

ratings apply for tank components, valves, solenoids, etc. Provide storage tank for designs requiring heavy demands.

Specify that recirculating pumps are to be Taco, Bell and Gosset, Grundfos, or approved equal. Pumps shall have sealed bearings that do not require lubrication. Pumps shall be accessible for maintenance and installed with a disconnect switch in sight of the unit. Pumps shall have a minimum one year warranty.

All drinking fountain units shall be UL listed and comply with A.R.I. Standard 1010. Units shall operate on 115V/60Hz and have a flow regulator accessible for adjustment.

Wall mounted drinking fountains shall be stainless steel Standard Dual Bi-Level unit with satin finish and a galvanized frame. Specify a TAS/ADA apron allowing frontal approach. Unit shall operate up to 105 psi while providing 8 GPH constant stream of water. Water controls shall operate with a maximum of 5 lbs. of force. If a bottle filling station is included in the design, specify an Elkay Halsey Taylor, or approved equal, Bi-Level ADA/TAS side approach filling station, sanitary, no-touch push activation bar operating with a maximum of 5lbs of force, water filter included with visual interface for replacement notification. Bottle filling station shall be “hands-free” automatic with a 30 second shut-off timer and be rated 1.1 GPM for refrigerated units 1.5 GPM for non-refrigerated units. Unit shall be lead-free and include antimicrobial protected plastic components to prevent mold and mildew.

Specify water closets to be American Standard, Kohler, or approved equal, either floor or wall mounted, siphon jet, elongated bowl, ADA/TAS compliant, white vitreous china unless specified otherwise, low water consumption, 1 ½” inlet, heavy duty open front solid plastic seat, meeting ASME A112.19.2-2008/CSA B45.1-08,

Specify urinals to be Sloan or approved equal with fixture/flushvalve, white vitreous china unless specified otherwise, HEU wall mount wash down with Integral trap and ¾” top spud and carrier, floor mounted carrier with hanger plate, adjustable supporting rods, rectangular structural uprights and welded feet. Water less urinals will be specified per the TTU PM’s request.

If waterless urinals are specified, specify touchless-free operation, sealed locking style cartridge (with the maintenance key for changing cartridges), odor-free, vitreous china, and white in color unless noted otherwise. Cartridges shall have a minimum of 7000 usages.

Specify angle stops and flush valves to be Sloan Royal or approved equal, quiet exposed permex rubber diaphragm type flushvalve with ADA Non-Hold-Open Handle, free spinning stop cap, no external volume adjustment, and is TAS compliant. Automatic flush sensor type valves to be Sloan or approved equal and battery operated. Install new batteries on substantial completion.

Specify water meters to be compound or turbine style suitable for the anticipated consumption of water usage in the facility. Meter shall be accessible for reading and maintenance and can be either located inside the building or in an outside vault at the tie-in location. Owner shall direct location.

Specify water hammer arrestors to be Watts or approved equal. Arrestors to be threaded for maintenance removal; sweat fittings are not preferred. Install in an accessible location.

Specify lavatories and sinks to be American Standard, Kohler or approved equals. Lavatories and sinks to be either vitreous china, stainless steel, acid resistant, or polymer/resin construction depending on the application and Owner's preference.

Do not allow use of plumbing fixtures for temporary facilities unless approved in writing by Owner.

Domestic Water Piping

This Section specifies requirements for furnishing and installing domestic hot and cold water piping, including hot water return, within buildings and underground within 10 feet of building.

Comply with AWWA Standards for public drinking water and Disinfecting Water Mains.

All buildings will be designed for metering of campus water. Domestic water shall have water meters installed either outside of the building or if approved by the Owner installed in the mechanical room of the building being served. Water meters up to 2 ½" shall be Onicon F-3000 series and water meters 3" and larger shall be Onicon F-3500 series. Meters shall communicate to BMS by BACnet via D-100 controller.

For underground piping sizes 4" and smaller, provide ASTM B 88, hard-drawn, Type K copper water tube with wrought copper fittings with socket ends, ANSI B16.22. Provide Sil-Fos lead-free solder for all solder joints.

For aboveground piping provide seamless, ASTM B 88, Type L copper water tube with ANSI B16.22 wrought copper fittings with socket ends. Provide lead-free solder for all solder joints. Solder shall be alloy Grade E in accordance with ASTM B32, equal to Engelhard Silvabrite 100.

Wrap all ductile iron fittings and valves in polyethylene sheet in accordance with AWWA C105.

Specify a reduced pressure backflow preventer sized as indicated on drawings, manufactured of bronze, rated for 175 psi, and shall include strainer, gate or ball valves based on size, pressure differential relief valve, check valves, test cocks, and relief vent and funnel drain. Unit shall meet the requirements of ASSE 1013, and AWWA, University of Southern California tested and approved. Manufactured by Watts Regulator No. 909, or approved equal by Wilkens or Flomatic.

Backflow prevention assemblies shall be tested upon installation by a recognized backflow prevention assembly tester and certified to operating within specifications. Test certifications will be provided to FP&C and TTU Physical Plant.

Revised 02-14-2018

Atmospheric vacuum breakers shall be full line size, manufactured of brass or bronze with full size orifice, dry guide out of the liquid pressure area and disc float closing vent with minimum flow. Manufactured by Watts Regulator, No. 188A Series, or approved equal by Wilkens or Flomatic. The water hydrostatic test pressure shall be a minimum 125 psi and a maximum of 1.5 times the working pressure. The pressure test shall be maintained for sufficient time to inspect all joints, with a minimum time of four hours.

Hot Water Heaters

Specify Patterson Kelley PK06, PK08, PK10 or approved equal.

Domestic Water Pumps

Specify complete factory assembled package tested, adjusted, and mounted securely on steel framing. Unit shall have two (2) pumps and a control panel with a main disconnecting switch that is inter-locked with the panel door. Units shall be sized for the Project demand. The pumping system shall be lead lag style with the secondary pump activating upon primary pump failure. The system as a whole unit shall have a five (5) year warranty. Domestic pump system to be Bell and Gossett, Grundfos, TACO or approved equals.

Sanitary Waste and Vent Piping

The Design Professionals and the FP&C Project Team will determine whether to specify cast iron or PVC piping for the sanitary waste and vent piping based on the project type and location.

For cast iron drain piping, specify piping to be service weight cast iron marked with collective trade mark of CISPI. Piping to be manufactured by Charlotte, Tyler, AB & I, or approved equal.

For underground cast iron drain piping within 5 ft. of building line, specify ASTM A74, service weight cast iron bell-and-spigot soil pipe and DWV pattern fittings with ASTM C 564 neoprene gaskets.

For underground PVC piping, specify Schedule 40 with solvent cemented joints.

For above ground cast iron piping, specify service weight cast iron no-hub soil pipe and DWV pattern fittings, conforming to ASTM A888-05 and most current version of CISPI 301. Provide CISPI 310, type 304 stainless steel heavy-duty 4-band no-hub couplings for pipe sizes 4" and less and 6-band no-hub couplings for pipe sizes over 4" with neoprene gaskets.

In no case shall PVC piping be installed in a return air plenum or supply/return ductwork without UL Listed and ASTM tested fire resistant plenum wrap. Plenum wrap to be 3M Fire Barrier Plenum Wrap 5A+ or approved equal.

For cast iron soil vent pipe and fittings, specify same as above grade piping indicated above. Provide heavy duty type 304 stainless steel minimum 4-band no-hub couplings, conforming to C.I.S.P.I. 310 as specified for drainage piping. Pipe shall conform to ASTM A 74, ASTM A 53 or ASTM B 306, where

applicable. For underground vent pipe and fittings, provide same as specified for underground drainage pipe and fittings.

In situations where wastewater temperatures exceed the PVC temperature ratings, cast iron or CPVC piping will be specified.

For piping below Floors, test pipe before backfilling and connecting to sewers by maintaining not less than 10' of hydrostatic head for 2 hours without a leak.

After all the various sections of soil, waste and vent piping are installed, but before fixtures are connected, test the system by plugging all outlets and filling vertical sections with water to maintain not less than 10 feet of hydrostatic head for a minimum of 2 hours without any drop in water level, for all sections of piping. Provide wyes as required to facilitate plugging. Cold weather testing will be an option upon Owner's approval and when excessive cold conditions exist.

Roof Drainage Piping System

The Design Professionals and the FP&C Project Team will determine whether to specify cast iron or PVC piping for the storm and overflow drainage piping based on the project type and location.

For cast iron drain piping, specify piping to be service weight cast iron marked with collective trade mark of CISPI. Piping to be manufactured by Charlotte, Tyler, AB & I, or approved equal.

For underground cast iron storm and overflow drainage piping within 5 ft. of building line, specify ASTM A74, service weight cast iron bell-and-spigot soil pipe and DWV pattern fittings with ASTM C 564 neoprene gaskets.

For aboveground cast iron storm and overflow drainage piping for sizes up to 10", specify, service weight cast iron no-hub soil pipe and DWV pattern fittings, conforming to ASTM A888-05 and most current version of CISPI 301, with CISPI 310 stainless steel heavy weight 4-band no-hub couplings for pipe sizes 4" and less and 6-band no-hub couplings for pipe sizes over 4" with neoprene gaskets, manufactured by Mission HW, Anaco "Husky 2000", Mi Fab XHUB, or approved equal. Pipe sizes over 10", shall be bell-and-spigot soil pipe.

For aboveground and underground PVC storm and overflow drainage piping, specify Schedule 40 PVC with solvent cemented joints. In no case shall PVC piping be installed in a return air plenum or supply/return ductwork. Do not use perforated underground piping.

For horizontal pipe joints, 1/8 bend and greater, provide angle braces to structure to restrain both lateral and longitudinal movement of piping.

For horizontal piping, provide angle braces to structure, at maximum 25' spacing, to restrain lateral pipe movement.

Specify to give horizontal pipe a minimum grade of 1/8" per foot, unless otherwise noted on drawings. Specify to use reduction fittings to connect two pipes of different diameter.

Revised 02-14-2018

Specify to change directions by appropriate use of 45-degree wyes; long-sweep quarter-bends, and sixth, eighth, and sixteenth-bends. Sanitary tees may be used on vertical stacks. Use long sweeps at the base of risers.

For underground piping, test pipe before backfilling and connecting to sewers. Maintain not less than 10 feet of hydrostatic head for 2 hours without a leak.

After all the various sections of roof drain piping are installed, test the system by plugging all outlets and filling vertical sections with water to maintain not less than 10' of hydrostatic head for 2 hours without any drop in water level, for all sections of piping. All sections with pipe joints shall be tested. Provide wyes as required to facilitate plugging. Provide test tees at bases of all roof drain risers for testing. Refer to latest edition of the International Plumbing Code for additional testing requirements.

Manhole Covers

Please reference Attachment 1 and 2 for the sanitary and storm water manhole covers. The castings are manufactured from grey iron ASTM A48 Class 35B iron. The ring is named in EJ's Dictionary as a V1420. and the Cover is a V1430.

Heating Ventilating and Air Conditioning (HVAC)

Specify Air Handling Units (AHU) shall have double walled casings of a minimum 18 gauge exterior and 20 gauge interior steel set on rails. Units shall provide access doors to areas that required entry for maintenance. Access doors to fan housings or blades shall have interlocking safety switches. Coils shall be designed to be capable of a minimum 16 degree delta T and be of copper with aluminum fins. Coils shall be a minimum of 8 rows and a maximum of 8 fins per inch to meet this requirement and allow the coils to be cleaned. Coil headers shall be red brass or approved material as specified by the Engineer. Provide positive drainage, sound attenuation, vibration control, and adequate locations for accessibility to unit. Filter media to meet the design parameters for the facility served and energy code minimum requirements. Units to have factory applied paint and touch will be required after installation. Each AHU shall have a dedicated internal light and receptacle. Units shall be internally insulated as required for sound attenuation. Motor bearings shall come with grease inserts accessible from outside the unit. Access doors shall have windows. Meet all ARI, ASTM, ASHRAE, and other standards that apply.

All fresh/outside air that is utilized with any associated AHU for any facility shall be pre-heated and tempered by means other than mixing only with return air. Steam pre-heat coils are preferred if steam is available, otherwise *comfort hot water shall be used. Any other systems being considered will require approval from FP&C.*

Chiller Units may be one of the following systems dependent upon design availability and restrictions; Air-cooled variable speed screw chillers, packaged heating and cooling, outdoor spilt systems or others as presented by the Engineer. The selection will be based on size of facility being served, energy consumption requirements, the campus tunnel system demand and availability at the specific location of the facility, and the remoteness of the tunnel system to the facility.

Specify hot water boilers for HVAC heating as hot water induced draft boiler with horizontal grid, finned tube heat exchanger, gas burning system complete with combustion chamber, controls, and trim. State inspections shall be scheduled by the Contractor and coordinated by the Owner. System shall meet all NFPA, ASME, ASTM, UL and FM Standards for the fabrication, installation, start-ups, and operation of the unit(s). Equipment to be Lochinvar, or approved equal.

Specify tube and shell steam converters to be "U" tube style converter with cupro-nickel tubes, carbon steel or brass baffles with a carbon steel tube sheet. Unless instructed by Owner, inlet and outlet connections shall be flanged. Unit shall be designed for low pressure steam and have a vacuum breaker for tube protection. The Engineer shall size the steam trap based off anticipated design loads.

Single and Dual Duct VAV Boxes

1. The air valves shall be of the dual duct or single duct type and shall be provided in a complete Package with control damper, electric actuator and variable air volume control assembly, etc. The damper shall be housed in a minimum 22 gauge galvanized steel housing of leak resistant construction with mechanical seal and with coated 1" thick insulation to resist erosion and to meet NFPA 90A and 90B requirements. The air valves shall be arranged either normally open or closed to meet the requirements of the hot or cold duct in which they are to be installed. Access to the damper and linkage shall be either through the outlet or through an access door. Scribe end of damper rod to indicate damper position. Secure damper linkage with indents and screws or through pins.
2. The DDC box controllers shall provide the characteristics of pressure independence so that the minimum and/or maximum CFM requirements of each space served will be obtained throughout the entire operating range of the air valve, regardless of the pressure changes in the system. Further the reset span of the electronic volume controller shall be adjustable for maximum and minimum air flow rate settings with fixed 2 deg. F. temperature range.
3. The Temperature Regulation Sub Contractor shall provide the DDC box controllers and electric actuators and deliver them to the unit manufacturer for his assembly of the air valve package. See Temperature Regulation Section. At the Contractor's option compatible actuators of other manufacture may be supplied with the terminals, and VAV box controllers may be field mounted.
4. A mixer-attenuator section is required on the discharge of the cold or hot and cold air valves if The assembly NC is greater than 35 at system pressure. Radiated sound shall not exceed 30 NC at 0.50 in. SP in. It shall be a minimum of 30" long.
5. The new either single duct (cold) or dual duct (hot and cold) air valves shall be installed in Accordance with the manufacturer's instructions. The unit shall be level +/-5 degrees to meet the operating requirements of the flow logic analyzer, which is attached to the side of the unit. Should it not be possible to level the terminal unit properly the flow logic analyzer will be removed, leveled and remounted. A minimum of 1-1/2 diameters of straight round duct is required ahead of the terminal unit so that the static pressure sensor of the pressure

independent control will function properly. Any turns or flexible duct will be ahead of the straight run. Maximum length of flexible ducts shall be 18".

If specified, Variable Refrigerant Flow (VRF) systems are to be a minimum of; variable capacity, heat pump heat recovery air conditioning utilizing variable refrigerant flow, 2-pipe, zoning to provide simultaneous heating and cooling via a split system heat pump and chiller. The system shall have an outdoor unit, controller, multiple indoor units and DDC controls. Indoor units can operate in either heating or cooling mode and can change with no interruption to system operation. Specify Mitsubishi Multi-City or approved equal as the basis of design.

Provide "Pete's Plugs" at all coil inlets and outlets.

Heating and cooling comfort settings will be dictated by FP&C and the TTU Physical Plant.

Ducts and Diffusers

Materials, fabrication, and installation shall meet the latest edition of the SMACNA Standard. Ducts shall be a minimum gauge that meets or exceeds the SMACNA "HVAC Duct Construction Standards", State, Federal, Local building and fire codes. Balancing dampers shall be provided at each branch of supply mains. Design of duct system (round, rectangular, oval, etc.) shall be coordinated with all other trades for clearances, maintenance, and proper air flows. Internally lined ducts are not preferred and will be allowed only with the Owner's consent. Dampers located above hard ceilings shall have extended balancing adjustment rods for manual adjustment. OBD grills are not preferred in the system. Ducts shall be tested according to SMACNA "HVAC Air Duct Leakage Test Manual".

Air and Dirt Separator

If required, specify Spirotherm air and dirt separator or approved equal.

Variable Frequency Drives (VFD)

Specify Toshiba or Yaskawa variable frequency drives or approved equal.

Controls and Instrumentation

Specify that building automation systems shall be compatible with existing Campus infrastructure and communicate with CHACP 1 (Central Heating and Cooling Plant I) located on the main campus. Labeling of control points on the monitoring system will be consistent with established University equipment labeling. All points will include the building name in the description for identification.

Specify to provide a complete working Building Automation System (BAS) of Direct Digital Controls (DDC), including any and all instrumentation necessary for a complete automatic control system as indicated by the requirements of the drawings and as specified herein. System shall be designed and installed so as to obtain all functions and results necessary or appropriate for the system(s), and as hereinafter specified. System shall be based on most current/latest version of hardware and software of the particular manufacturer.

Revised 02-14-2018

The automatic temperature control system shall be a microprocessor based Direct Digital Control (DDC), Building Automation System (BAS) utilizing a combination of electric/ electronic components, as indicated. The entire system shall be provided by an approved Controls Manufacturer/ Contractor, Johnson Controls Inc. or ConTech. It shall be designed by experienced engineers and installed by competent technicians, all of which are regularly employed in the specialty field of HVAC and building controls. This system/ installation shall include temperature control components, interlock relays, and all associated electrical conduit and conductors. When adding new controls to existing buildings, verify with CHACP 1 of the current Building Automation System (BAS); new controls shall match existing system controls. In the event of a major renovation to a building, if applicable, the entire system shall be upgraded.

Control work includes, but is not necessarily limited to, the following systems:

1. Unitary HVAC equipment controls.
2. Packaged air conditioning unit (PACU) humidity control and high humidity override.
3. DX AHU system(s) and activation/control of zone electric duct heater.
4. Exhaust fans start/stop or enable/disable.
5. Demand controlled ventilation via CO2 sensing.
6. Monitor of fire sprinkler system alarms.
7. Monitor of lift station alarm.
8. Building automation/energy management.
9. Controls wiring and other interfaces as required for fire alarm shutdown of air systems.
10. Additional control systems and components as indicated by the drawings, as specified herein, or as necessary to accomplish the work described.
11. Monitoring, status, and alarm functions as specified in this Section, as indicated in related sections of equipment being controlled, and as indicated on drawings. Minimum points to monitor are listed in the chart below.

AHU's
OUTSIDE AIR TEMPERATURE SENSOR
RETURN AIR TEMPERATURE
MIXED AIR TEMPERATURE
DISCHARGE AIR TEMPERATURE
LOW LIMIT TEMPERATURE
CHILLED WATER VALVE
OUTSIDE AIR DAMPER
RETURN AIR DAMPER
RELIEF AIR DAMPER
FILTER STATUS
RETURN FAN COMMAND & STATUS
RETURN FAN SPEED
SUPPLY FAN COMMAND & STATUS

Revised 02-14-2018

SUPPLY FAN SPEED
HIGH STATIC ALARM
DISCHARGE AIR STATIC PRESSURE
TERMINAL UNITS
SUPPLY AIR TEMP
SPACE TEMP
COOLING
HEATING
FAN
SINGLE ZONE RTU's
OUTSIDE AIR TEMP (1 per building)
RETURN AIR TEMP
SUPPLY AIR TEMP
SPACE TEMP
COOLING
HEATING
FAN
FAN STATUS
CHILLED/HEATING WATER SYSTEMS
CHILLED WATER SUPPLY METER
CHILLED WATER PUMP
CHW SUPPLY / RETURN TEMP
HOT WATER PUMP
HWS SUPPLY / RETURN TEMP
STEAM
STEAM SUPPLY METER

For Emergency Maintenance (EM), graphic screens for HVAC systems should show the air handling units, their locations and room numbers.

The manufacturer/contractor shall maintain local qualified and experienced designer, programmer and service technician, familiar with the details of this project/system, to serve the project throughout the warranty period. Such personnel shall be available on a 24-hour, seven day a week basis, and contractor/manufacturer shall provide equally qualified substitutes during such personnel's "absentee" periods.

The Contractor shall have not less than a five (5) year experience record in the design and installation of computerized building systems similar in geographic vicinity, scope, and performance to that specified herein. References will be made available upon request.

Quality assurance for automatic controls systems shall be accomplished through the Contractor's commissioning process.

Revised 02-14-2018

The automatic controls will be installed under the direct and continuous supervision of a lead technician who is an employee of the manufacturer or an approved representative of the manufacturer (approved by the manufacturer and acceptable to the Owner).

Service personnel shall be available at all times during the warranty period, and after hours calls and response shall be provided without additional cost to the Owner.

The system shall be approved and listed by Underwriters' Laboratories, Inc., under UL916 for energy management systems.

The system shall be certified to comply with NEC (NFPA70), FCC-Part J, and ASHRAE/ANSI Standard 135 (BACnet).

The Controls Manufacturer/Contractor shall verify, prior to proposal, that sequences of operation and control approaches presented within the drawings and these specifications are appropriate for the HVAC systems and equipment to be used, and that its systems to be provided are complete.

The Controls Manufacturer/Contractor shall coordinate design and installation of the controls system with the fire alarm system and TTU CHACP1.

The Controls Contractor or Subcontractor shall coordinate proposing/ bidding and execution of the work with that of other trades, including mechanical (ducting), testing, adjusting, and balancing, and electrical (including fire alarm). Full cooperation and coordination with the other trades shall be required. The controls contractor/subcontractor shall be responsible for verifying proper installation (to be done by mechanical trades) of all wells, ports, taps, etc. needed for installation of all control and instrumentation devices.

Specify All equipment, components, parts, materials, peripherals, etc. provided shall be the latest current versions offered by the respective manufacturer, and shall be fully compatible with all other equipment, etc. provided at any other time throughout the warranty period plus 4 years. Should updated versions of equipment be provided which are not fully compatible with earlier equipment provided (e.g. a requirement to add hardware or software "interfacing" between an earlier and later generation results in the systems not being fully compatible), Controls Contractor and Manufacturer shall replace earlier equipment with the later version at Controls Contractor's and Manufacturer's cost. This requirement shall be a binding warranty which applies regardless of the expiration of other warranties. By offering a proposal for this work, the Controls Contractor and Manufacturer both agree with and shall be bound by this requirement.

Specify all software used in/supplied to this system shall be the manufacturer's current/latest version. All software upgrades applicable to system and offered by the manufacturer/contractor for this system shall be provided at no cost to the Owner throughout the warranty period plus four years. This no cost upgrade shall include installation, programming, (sequence, color graphics, reports, etc.) modifications to field equipment, data base revisions, etc., all as appropriate.

All project developed hardware and software shall become the property of the Owner. These properties include but are not limited to: Project graphic images, record drawings, project database, job-specific application programming code, and all documentation. All workstation graphics shall be developed and installed by the Contractor. Each building shall be provided with a main graphic to which other building specific graphics shall be linked. Links shall be embedded on each floor plan that navigates to an enlarged floor plan. The Building Main Graphic shall also display the building current active alarm count, links to all building specific graphics, links to all menu/navigation graphics and building restart graphics. Provide an enlarged floor plan, which shall display room temperatures and provide links to Building Equipment Level graphics. On each floor plan graphic, provide navigation links to all building levels and menus with links to other building graphics. Provide one graphic for each HVAC system including fan systems, chilled water systems, hot water systems, steam systems, return fan systems and other systems as appropriate for project specifics.

Minimum graphics update rates:

- Display Refresh: 20 dynamic points in 10 seconds, with automatic refresh every 20 seconds
- Object Command: 5 seconds
- Object Scan: 5 seconds
- Alarm Response Time: 5 seconds when point goes into alarm
- Multiple alarms: 3 seconds of each other

The Control Contractor/Manufacturer shall submit shop drawings of the entire control system complete with specification data sheets for all instrumentation, etc., before starting work. Shop drawings shall be neat and professionally prepared

Specify all products shall be of a single manufacturer wherever possible. Should a single manufacturer not have all products available from its product line, a minimum number of manufacturers shall be used. Each manufacturer, and quantity of manufacturers, shall be subject to the acceptance of the Design Professional and Owner. In all cases, all like devices/equipment shall be of a single manufacturer. Specify to provide all sensors, thermostats, dampers (control), operators, microprocessors, controllers, transducers, switches, indicating devices, interface equipment, transformers, power supplies, fuses, wiring, cabling, and other devices/apparatus required to properly operate mechanical system and to perform functions specified and intended.

Provide controllers that execute PID control loops at a frequency not to exceed 3 seconds. The process variable scan and updated calculated output is at the same frequency rate.

Control Loop Stability:

- Air Pressure: $\pm 0.3''$ wg
- Airflow: $\pm 5\%$ of actual flow
- Temperature: $\pm 2^\circ\text{F}$
- Humidity: $\pm 5\%$ RH
- Fluid Pressure: $\pm 3\%$ of full scale
- Fluid Flow: $\pm 3\%$ of full scale

Revised 02-14-2018

Where recommended by controls manufacturer for the system/application involved, DDC system/components shall employ and maintain a separate, "clean earth" grounding protection. "Mixing" of grounding systems shall be prohibited.

Specify electrical materials and installation shall be in accordance with the requirements of NFPA, the National Electrical Code, and the Project's electrical specification. All electrical work included under this section shall be complete with labor, materials and installations. Electrical Contractor is to install 120V power to each terminal box and each DDC panel per Division 16.

Label all instrumentation and controls and associated conduit and cabling with clearly visible and readable identification with respect to the control record drawings and the equipment served.

When installation of system is complete, calibrate all sensors and related equipment and verify transmission media operation before the system is placed on-line. All testing, calibrating, adjusting, and final field tests shall be completed by the Contractor.

Except as noted below, all wire/cable (in walls, chases, mechanical rooms, below grade, below slabs, above ceilings, etc.) shall be run in conduit. Conduit types shall match those in the electrical division with regard to types (e.g. RGS,IMC, EMT) in particular spaces. An exception may be allowed on certain situations with the Owners consent to run control wire/cable outside of conduit if all the following conditions prevail: allowed by NFPA 72; located above accessible ceilings; plenum rated cable is used; less than 24 VAC or 24 VDC (nominal) is used; where allowed by all applicable administrative authorities; where labeled "controls" and supported in accordance with code.

Unless otherwise indicated, all conduits shall be concealed and square with building lines. In addition, comply with special requirements for conduit routing to avoid exposed placement.

At a minimum, each contractor and all materials/equipment suppliers shall guarantee all labor and materials furnished by respective entity for a period of one year unless otherwise noted. Warranty period shall extend from the date of substantial completion or upon written directive from the Owner, whichever occurs first. The warranty shall cover the repair or replacement, at the Contractor's expense, of any defective material, faulty workmanship, or incompleteness.

The building automated system shall have an adjustable "dead band" of four (4) degrees controlling both the heating and the cooling. Building occupants shall have the capability to utilize this feature by using an override on the thermostats in their respected areas.

The temperature control shall have a programmed seasonal set-point range that will be provide by the Owner prior to the system being accepted. It is the controls contractor's responsibility to ensure these parameters are incorporated into the submittal package prior to work commencing.

System Cleaning

System cleaning is required for the following systems: Chill water closed loops, hot water loops, and condenser water systems.

Specify the following minimums for cleaning of the piping systems:

1. Remove flow meters from building piping during flushing operation. Provide means (instrumentation) during flushing period to prove to the Owner Representative that the minimum velocities are maintained in the pipes. Submit a detailed cleaning plan for the Engineer's and Owner's review and approval describing in full detail the individual steps associated with this process. Plan must include a drawing indicating GPM's required to provide minimum velocity required in the piping, phasing of systems being cleaned, locations of drains or other temporary connections required for system cleaning. Submit chemicals to be used for cleaning the system for Owner and Engineer approval.
2. Clean piping systems thoroughly. Purge pipe of construction debris and contamination before placing the systems in service. Provide whatever temporary connections and valves that are required for cleaning, purging and circulating. Provide temporary bypasses around air handling units, fan coil units, flow meters and hot water coils.
3. The pipe cleaning of the building will also include the cleaning of any new tunnel piping that serves the building.
4. The piping mains shall be flushed and cleaned prior to the installation of laterals.
5. Install temporary strainers in front of pumps, tanks, water still, solenoid valves, control valves, and other equipment where permanent strainers are not indicated. Keep these strainers in service until the equipment has been tested, then remove either entire strainer or straining element only. Fit strainers with a line size blow off valve. Provide backflow protection for the domestic water when connected to the system being flushed.
6. Circulate a chemical cleaner in chilled, heating, condenser water piping systems to remove mill scale, grease, oil and silt. Circulate Owner approved detergent with Owner approved anti-foam compound. Circulate for 48 hours or as required by Owner, flush system and replace with clean water. Dispose of circulated water with chemicals as per local code requirements. Submit all chemicals to Owner/Engineer prior to cleaning for approval.
7. Provide water treatment chemicals in piping systems as directed by Owner. Chemicals must be compatible with the chemicals in the existing distribution system. Owner will review and approve chemicals submitted.

Disinfection of Potable Water System

All new, altered, or repaired potable water system piping and tanks shall, after successful pressure testing, be thoroughly flushed with clean potable water and then disinfected prior to utilization/final connection in strict accordance AWWA C651. The preliminary flushing velocity in the main shall not be less than 2.5 ft/sec unless the owner determines that conditions do not permit the required flow to be discharged to waste. Disinfection shall be with either liquid chlorine or chlorine granules (no tablets allowed) of adequate volume to give a water/chlorine solution concentration of 25 ppm (250 mg/L) based upon the volume of the system being treated. The solution will be allowed to stand for a period of 24 hours. If the water temperature is less than 41°F, the water shall remain in the pipe at least 48 hours. A detectable free chlorine residual should be found at each sampling point after the 24 or 48 hour period. Sample points will be selected in accordance with AWWA C651. After final flushing with

Revised 02-14-2018


clean potable water and before the new water main is connected to the distribution system, two consecutive sets of acceptable samples, taken at least 24 hours apart, shall be collected from the new main. At least one set of samples shall be collected from every 1,200 ft. of the new water main, plus one set from the end of the line and a least one set from each branch. The procedure shall be repeated where shown by a bacteriological test that contamination remains in the present system. The above are minimum requirements and all disinfection procedures shall be in strict accordance with the International Plumbing Code, AWWA, TCEQ, Texas Administrative Code (TAC), all local codes and authorities having jurisdiction. The record of compliance shall be the bacteriological test results certifying that the water sampled from the new water main is free of coliform bacteria contamination, absent from free chlorine residual, and is equal to or better than the bacteriologic water quality in the distribution system. Under no circumstances shall the Contractor permit the use of any portion of the domestic water system until the Owner has received a Biological Contamination Reports from a certified testing lab stating that the systems are clean and the system is safe for human consumption.

In lieu of the 25 ppm for 24 hours requirement, filling the system with a water/chlorine solution of 200 ppm or greater and allowing it to stand for a minimum of 3 hours will only be allowed with the Owner's permission.

The Contractor shall be responsible for the disposal of all domestic water with chemicals resulting from new construction. Water shall be disposed per Owner, State and local requirements.

Contractor to use the City of Lubbock Water Microbiology Laboratory (806-775-2907) for potable water testing. The lab is located at 6001 N. Guava.

V1420Z1 V1430A Assembly



Product Number
 414300013AD1
Design Features
 -Materials
 Frame
 Grey Iron (CL368)
 Cover
 Grey Iron (CL368)

-Design Load
 Heavy Duty
 -Open Area
 r/s
 -Coating
 Unliped
 -✓ Designate Machined Surface

Certification
 -ASTM A48
 -
 -Country of Origin: USA

Major Components
 41420012
 414300013



Drawing Revision
 1/8/2014 Designer: MAH
 Revised By:

Disclaimer
 While in this drawing (reference) and drawings provided for your guidance, we reserve the right to modify specifications without prior notice.
CONFIDENTIAL: This drawing is the property of EJ GROUP, Inc., and contains confidential information, registered marks, patents, trade secret information, and/or know-how that is the property of EJ GROUP, Inc. Copyright © 2018 EJ GROUP, Inc. All rights reserved.

Contact
 800 620 4663
 ejco.com

Attachment 1 – Sanitary Sewer Manhole Cover

V1420Z1 V1430A Assembly



Product Number
 414300014A01
Design Features
 -Materials
 Frame
 Gray Iron (CL36B)
 Cover
 Gray Iron (CL36B)

-Design Load
 Heavy Duty
 -Open Area
 n/a
 -Coating
 Unpiped
 -✓ Designate Machined Surface

Certification
 -ASTM A48
 -
 -Country of Origin: USA

Major Components
 41420012
 414300014

Drawing Revision
 1/8/2014 Designer: MAH
 Revised By:

Disclaimer
 Weights (in lbs) dimensions (in millimeters) and drawings provided for your guidance. We reserve the right to modify specifications without prior notice.
CONFIDENTIAL: This drawing is the property of EJ GROUP, Inc. and contains confidential information, registered marks, patents, trade secret information and/or know how that is the property of EJ GROUP, Inc. Copyright © 2008 EJ GROUP, Inc. All rights reserved.


Contact
 800 828 4863
 @003031

Attachment 2 – Storm Sewer Manhole Cover


Revised 02-14-2018




V1430A Cover



BOTTOM VIEW



SECTION



PICKHOLE DETAIL

Product Number
 NPR14-4228

Design Features

- Materials
 Gray Iron (CL35B)
- Design Load
 Heavy Duty
- Open Area
 n/a
- Coating
 Undipped
- √ Designates Machined Surface

Certification

- ASTM A48
- Country of Origin: USA

Drawing Revision
 10/17/2014 Designer: MAH
 Revised By:

Disclaimer
 Weights (lbs/kg) dimensions (inches/mm) and drawings provided for your guidance. We reserve the right to modify specifications without prior notice.

CONFIDENTIAL: This drawing is the property of EJ GROUP, Inc. and embodies confidential information, registered marks, patents, trade secret information, and/or know how that is the property of EJ GROUP, Inc. Copyright © 2012 EJ GROUP, Inc. All rights reserved.

Contact
 800 626 4653
 ejco.com

Attachment 3 – Communications Manhole Cover